

FMT

Florida Marine Transporters, Inc.

675 N. Causeway Blvd.
Mandeville, LA 70448
(985) 629-2082 Phone
(985) 629-2110 Fax

HOSE AND PIPELINE TESTS

VESSEL: FMT 3076

THE FOLLOWING ITEMS HAVE BEEN CHECKED AND TESTED IN ACCORDANCE WITH
46CFR 35.35-70 AND 33CFR 156.170 ON 6-4-24.

✓

PRESSURE GAUGES HAVE BEEN CHECKED
WITHIN 10% OF ACCURACY.

✓

EMERGENCY SHUTDOWN HAS BEEN CHECKED
AND FOUND OPERABLE.

✓

TRANSFER SYSTEM RELIEF VALVE HAS BEEN
TESTED AND CHECKED - 125 P.S.I.

✓

ALL TRANSFER PIPING SYSTEMS AND
ASSOCIATED VALVES HAVE BEEN TESTED
AND CHECKED AT 187.5 P.S.I.

N/A

CARGO HOSE VISUALLY AND
HYDROSTATICALLY CHECKED TO 225 P.S.I.

THE ABOVE ITEMS CHECKED, TESTED AND VERIFIED BY:

Dal Me

2360 Fifth Street
Mandeville, LA 70471
Phone (985) 629-2082 Fax (985) 629-2120

Florida Marine
Transporters Inc.

MARINE VESSELS VAPOR TIGHTNESS DOCUMENTATION

REQUIRED SUBPART BB-NATIONAL EMISSION STANDARDS FOR BENZENE EMISSIONS FROM TRANSFER
OPERATIONS SECTION 61.00-61.306

VESSEL: FMT 3076 OFFICIAL NUMBER: 111 9272
TESTING LOCATION: CUMMINGS FLT MAXIMUM LOADING RATE (BPH) 5,000
TANK(S) TESTED: ALL PRESSURE INDICATOR: MANOMETER
VESSEL OWNER AND ADDRESS: FMT 2360 FIFTH ST. MANDEVILLE

TEST RESULTS

TEST DATE: 6-4-24
BEGINNING PRESSURE: 28" OF H₂O BEGINNING TIME: 1230
ENDING PRESSURE: 28" OF H₂O ENDING TIME: 1300
TOTAL PRESSURE LOSS: 0 ALLOWABLE PRESSURE LOSS: 2.2" OF H₂O

NOTE: VESSEL IS CONSIDERED VAPOR TIGHT IF "TOTAL PRESSURE LOSS" IS LESS THAN "ALLOWABLE PRESSURE LOSS"

THIS VESSEL HAS BEEN TESTED IN ACCORDANCE WITH SECTION 61.304F, AND IS
CONSIDERED VAPOR TIGHT.

TESTER: DAVID MCNEMAR (PRINT) WITNESS: ROBERT MCNEMAR (PRINT)
TESTER: [Signature] (SIGN) WITNESS: [Signature] (SIGN)

AFFILIATION OF WITNESS

CALCULATION OF ALLOWABLE PRESSURE LOSS:

$$0.861 \times \frac{15.7}{(TP)} \times \left(\frac{5,000}{(L)} \div \frac{30,706}{(V)} \right) = \frac{2.2}{(APL)}$$

TP = 14.7 PLUS THE BARGE TEST PRESSURE IN PSI (1psi = 16 ounces)
L = MAXIMUM LOADING RATE IN BARRELS PER HOUR
V = VOLUME OF TANK(S) IN BARRELS
APL = ALLOWABLE PRESSURE LOSS IN INCHES OF WATER

NOTES: 14.70psi = 406.8 inches of H₂O
1psi = 27.67 inches of H₂O
1 inch = 25.40 mm
1 inch = 2.54 cm
1oz. = 1.729 inches OF H₂O